



Product Service

CERTIFICATE

No. Z10 16 09 68122 016

Holder of Certificate: Recherche 2000 Inc.
380 St-Antoine West, Suite 7500
Montreal QC H2Y 3X7
CANADA

Factory(ies): 68122

Certification Mark:



Product: Safety components

Model(s): MODA sensor and SFOCOM logic solver
EH510 (MODA) and EH630 (SFOCOM)
Used with: EH500-4 (TFP) and EH600 (SILCAM)

Parameters:

Safety parameter:	
Safety Integrity Level (SIL)	2
Proof Test Interval (T1)	1 year

Tested according to:

- IEC 61508-1(ed.2) (SIL 2)
- IEC 61508-2(ed.2) (SIL 2)
- IEC 61508-3(ed.2) (SIL 2)
- IEC 61508-4(ed.2) (SIL 2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: RM85552T

Valid until: 2021-09-05

Peter Weiss

Date, 2016-09-06 (Peter Weiss)



Page 1 of 1